

Discharge Point Monitoring Results Ballyclerihan WWTP - 2012

Parameter	BOD (mg/l)	COD (mg/l)	SS (mg/l)	Amm (mg/l)	Ortho P (mg/l)	TN (mg/l)	pH
ELV (mg/l)	10	125	10	1	0.5	20	6 to 9
January	5	15	3	0.1	0.11	5.1	7.8
February	4	15	4	0.1	0.15	11.7	7.7
March	3	17	4	0.1	0.07	6.4	7.8
April	2	15	5	0.1	0.03	11.2	7.4
May	2	15	3	0.7	0.03	5.6	7.3
June	2	10	3	0.1	0.03	2.2	7.9
July	2	15	3	0.1	0.19	6.2	7.7
August	2	20	3	0.1	0.06	3.9	7.9
September	2	17	3	0.1	0.1	11.3	8.1
October	3	15	3	0.1	0.12	3.2	7.7
November	3	15	6	0.8	0.23	18	7.4
December	NT	15	3	0.1	0.09	15.2	7.6