

* Accredited **Sub-Contract ***Accredited Sub-Contract				Para-meter	Coliform Bacteria	Conductivity @ 20°C	E Coli	pH	Turbidity	Colony Count @ 22°C	Colour (Apparent)	Odour (D)	Taste (D)	Free Chlorine	Nitrate NO3	Total Chlorine	Aluminium	Ammonium NH4	Fluoride		
<b>REGULATED GROUP WATER SCHEMES ~ DRINKING WATER COMPLIANCE MONITORING YEAR 2022. GROUP A PARAMETERS.</b>				Max.	0	2500	0	9.5	1	200	20	--	--	2	50	2	200	0.3	0.8		
				Min.	--	--	--	6.5	--	--	--	--	--	--	--	--	--	--	--	--	0.6
				Test Method	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Entity	Entity Reference	Sample Template	Sample Date	Analyst Conclusion	MPN/100mls	µS/cm	MPN/100mls	pH units	NTU	no./1ml	Pt-Co	Descrip-tive	Descrip-tive	mg/l	mg/l	mg/l	µg/l	mg/l	mg/l		
Abbeyville Lorrha	2800PRI2156	GWS - Group A Parameters	16-Mar-2022	-	0 ***	716 ***	0 ***	7.1 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.24	20.44 ***	0.25					
Abbeyville Lorrha	2800PRI2156	GWS - Group A Parameters	15-Nov-2022	-	0 ***	701 ***	0 ***	7.3 ***	0.25 ***	<1 ***	<5 ***	OK	OK	0.12	22.32 ***	0.17					
Ardconey	2800PRI2043	GWS - Group A Parameters	17-Jan-2022	-	0 ***	669 ***	0 ***	7.3 ***	0.27 ***	<1 ***	13 ***	OK	OK	0.12	32.29 ***	0.21					
Ardconey	2800PRI2043	GWS - Group A Parameters	28-June-2022	-	0 ***	663 ***	0 ***	7.2 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.87	27.11 ***	1.01					
Ardconey	2800PRI2043	GWS - Group A Parameters	14-Sep-2022	-	0 ***	638 ***	0 ***	7.3 ***	<0.2 ***	7 ***	<5 ***	OK	OK	0.02	25.63 ***	0.04					
Ardconey	2800PRI2043	GWS - Group A Parameters	1-Nov-2022	-	0 ***	627 ***	0 ***	7.3 ***	1.34 ***	8 ***	41 ***	OK	OK	0.04	31.77 ***	0.24					
Ashill	2800PRI2126	GWS - Group A Parameters	24-Jan-2022	-	0 ***	726 ***	0 ***	7.2 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.45	8.93 ***	0.55					
Ashill	2800PRI2126	GWS - Group A Parameters	30-May-2022	-	0 ***	722 ***	0 ***	7.1 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.49	5.84 ***	0.62					
Ballinderry	2800PRI2021	GWS - Group A Parameters	15-Mar-2022	-	0 ***	706 ***	0 ***	7.5 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.44	26.47 ***	0.47					
Ballinderry	2800PRI2021	GWS - Group A Parameters	7-July-2022	-	0 ***	688 ***	0 ***	7.6 ***	0.32 ***	<1 ***	<5 ***	OK	OK	0.66	24.02 ***	0.71					
Barnane	2800PRI2078	GWS - Group A Parameters	31-Jan-2022	-	0 ***	533 ***	0 ***	7.2 ***	<0.2 ***	1 ***	<5 ***	OK	OK	0.49	5.01 ***	0.5					
Barnane	2800PRI2078	GWS - Group A Parameters	13-Sep-2022	-	0 ***	525 ***	0 ***	7.1 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.65	6.82 ***	0.66					
Bawn/Kilriffith	2800PRI2001	GWS - Group A Parameters	17-Jan-2022	-	0 ***	572 ***	0 ***	7.6 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.5	15.03 ***	0.54					
Bawn/Kilriffith	2800PRI2001	GWS - Group A Parameters	28-June-2022	-	0 ***	522 ***	0 ***	7.5 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.39	11.7 ***	0.45					
Bawn/Kilriffith	2800PRI2001	GWS - Group A Parameters	21-Sep-2022	-	0 ***	504 ***	0 ***	7.7 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.28	11.66 ***	0.36					
Bawn/Kilriffith	2800PRI2001	GWS - Group A Parameters	22-Nov-2022	-	0 ***	578 ***	0 ***	7.7 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.39	15.15 ***	0.44					
Brittas	2800PRI2165	GWS - Group A Parameters	23-Mar-2022	-	0 ***	753 ***	0 ***	7.5 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.76	6.75 ***	0.76					
Brittas	2800PRI2165	GWS - Group A Parameters	25-Oct-2022	-	0 ***	637 ***	0 ***	7.4 ***	<0.2 ***	<1 ***	6 ***	OK	OK	0.46	6.74 ***	0.48					
Carrigahorig / Milford	2800PRI2027	GWS - Group A Parameters	15-Mar-2022	-	0 ***	657 ***	0 ***	7.7 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.53	39.59 ***	0.54					
Carrigahorig / Milford	2800PRI2027	GWS - Group A Parameters	28-June-2022	-	0 ***	676 ***	0 ***	7.3 ***	<0.2 ***	1 ***	<5 ***	OK	OK	0.36	37.07 ***	0.41					
Carrigahorig / Milford	2800PRI2027	GWS - Group A Parameters	14-Sep-2022	-	0 ***	671 ***	0 ***	7.4 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.43	37.07 ***	0.44					
Carrigahorig / Milford	2800PRI2027	GWS - Group A Parameters	1-Nov-2022	-	0 ***	669 ***	0 ***	7.4 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.34	39.97 ***	0.38					
Castelcranna / Carrigatogher	2800PRI2041	GWS - Group A Parameters	26-Jan-2022	-	0 ***	503 ***	0 ***	7.7 ***	0.52 ***	128 ***	<5 ***	OK	OK	0.02	<1.11 ***	0.04					
Castelcranna / Carrigatogher	2800PRI2041	GWS - Group A Parameters	21-Sep-2022	-	0 ***	514 ***	0 ***	7.9 ***	0.2 ***	<1 ***	7 ***	OK	OK	0	<1.11 ***	0					
Castleiney A	2800PRI2045	GWS - Group A Parameters	31-Jan-2022	-	0 ***	711 ***	0 ***	7.1 ***	0.38 ***	4 ***	<5 ***	OK	OK	0.03	27.55 ***	0.05					
Castleiney A	2800PRI2045	GWS - Group A Parameters	13-Sep-2022	-	0 ***	700 ***	0 ***	7.2 ***	<0.2 ***	16 ***	<5 ***	OK	OK	0.02	21.36 ***	0.03					
Corbally Portroe	2800PRI2311	GWS - Group A Parameters	1-Feb-2022	-	0 ***	204 ***	0 ***	6.7 ***	<0.2 ***	8 ***	<5 ***	OK	OK		7.38 ***						
Corbally Portroe	2800PRI2311	GWS - Group A Parameters	4-Oct-2022	-	0 ***	331 ***	0 ***	7.1 ***	0.23 ***	<1 ***	<5 ***	OK	OK		8.1 ***						
Couraguneeen	2800PRI2387	GWS - Group A Parameters	19-Jan-2022	-	0 ***	483 ***	0 ***	7.7 ***	<0.2 ***	<1 ***	<5 ***	OK	OK		9.26 ***						
Couraguneeen	2800PRI2387	GWS - Group A Parameters	26-Oct-2022	-	0 ***	482 ***	0 ***	7.5 ***	<0.2 ***	6 ***	<5 ***	OK	OK		9.07 ***						
Cunnahurt/Knockalton	2800PRI2009	GWS - Group A Parameters	26-Jan-2022	-	0 ***	749 ***	0 ***	7.2 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.15	40.7 ***	0.28					
Cunnahurt/Knockalton	2800PRI2009	GWS - Group A Parameters	20-Sep-2022	-	0 ***	750 ***	0 ***	7.6 ***	<0.2 ***	>300 ***	<5 ***	OK	OK	0.04	41.43 ***	0.09					
Drombane Ballina	2800PRI2100	GWS - Group A Parameters	1-Feb-2022	-	0 ***	387 ***	0 ***	7.7 ***	<0.2 ***	38 ***	<5 ***	OK	OK	0.16	11.92 ***	0.18					
Drombane Ballina	2800PRI2100	GWS - Group A Parameters	4-Oct-2022	-	0 ***	387 ***	0 ***	7.5 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.19	12.77 ***	0.19					
Drombane Upperchurch	2800PRI2031	GWS - Group A Parameters	18-Jan-2022	-	0 ***	435 ***	0 ***	7.6 ***	0.8 ***	>300 ***	21 ***	OK	OK	0.06	9.52 ***	0.11					
Drombane Upperchurch	2800PRI2031	GWS - Group A Parameters	9-Nov-2022	-	0 ***	417 ***	0 ***	7.4 ***	0.22 ***	<1 ***	<5 ***	OK	OK	0.18	7.12 ***	0.19					
Elmhill / Ballymackey	2800PRI2018	GWS - Group A Parameters	26-Jan-2022	-	0 ***	422 ***	0 ***	7.1 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.11	6.63 ***	0.26	19 ***		0.7 ***		
Elmhill / Ballymackey	2800PRI2018	GWS - Group A Parameters	20-Sep-2022	-	0 ***	396 ***	0 ***	7.3 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.48	1.68 ***	0.68	92 ***		0.6 ***		
Fantane	2800PRI2051	GWS - Group A Parameters	8-Feb-2022	-	0 ***	437 ***	0 ***	7.2 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.34	28.17 ***	0.37					
Fantane	2800PRI2051	GWS - Group A Parameters	13-Sep-2022	-	0 ***	442 ***	0 ***	7.1 ***	<0.2 ***	11 ***	<5 ***	OK	OK	0	27.4 ***	0.01					
Frolic Carney	2800PRI2034	GWS - Group A Parameters	15-Mar-2022	-	0 ***	660 ***	0 ***	7.4 ***	<0.2 ***	10 ***	<5 ***	OK	OK	0.87	31.92 ***	0.9					
Frolic Carney	2800PRI2034	GWS - Group A Parameters	7-July-2022	-	0 ***	769 ***	0 ***	7.4 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.65	49.98 ***	0.71					
Garrynamona	2800PRI2024	GWS - Group A Parameters	18-Jan-2022	-	0 ***	712 ***	0 ***	7.2 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.3	27.55 ***	0.38					
Garrynamona	2800PRI2024	GWS - Group A Parameters	29-Mar-2022	-	0 ***	716 ***	0 ***	7.4 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.73	44.33 ***	0.96					
Garrynamona	2800PRI2024	GWS - Group A Parameters	18-Oct-2022	-	0 ***	744 ***	0 ***	7.4 ***	<0.2 ***	4 ***	<5 ***	OK	OK	0.62	30.68 ***	0.73					
Garrynamona	2800PRI2024	GWS - Group A Parameters	13-Dec-2022	-	0 ***	716 ***	0 ***	7.3 ***	<0.2 ***	1 ***	<5 ***	OK	OK	0.9	41.1 ***	1					
Graigue Pouldine Zone 1: Graigue	3700PRI0405	GWS - Group A Parameters	18-Jan-2022	-	0 ***	644 ***	0 ***	7.2 ***	<0.2 ***	2 ***	<5 ***	OK	OK	0.35	19.32 ***	0.42					
Graigue Pouldine Zone 1: Graigue	3700PRI0405	GWS - Group A Parameters	9-Nov-2022	-	0 ***	648 ***	0 ***	7.1 ***	<0.2 ***	61 ***	<5 ***	OK	OK	0.22	16.96 ***	0.35					

* Accredited **Sub-Contract ***Accredited Sub-Contract				Para-meter	Coliform Bacteria	Conductivity @ 20°C	E Coli	pH	Turbidity	Colony Count @ 22°C	Colour (Apparent)	Odour (D)	Taste (D)	Free Chlorine	Nitrate NO3	Total Chlorine	Aluminium	Ammonium NH4	Fluoride		
<b>REGULATED GROUP WATER SCHEMES ~ DRINKING WATER COMPLIANCE MONITORING YEAR 2022. GROUP A PARAMETERS.</b>				Max.	0	2500	0	9.5	1	200	20	--	--	2	50	2	200	0.3	0.8		
				Min.	--	--	--	6.5	--	--	--	--	--	--	--	--	--	--	--	--	0.6
				Test Method	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--
Entity	Entity Reference	Sample Template	Sample Date	Analyst Conclusion	MPN/100mls	µS/cm	MPN/100mls	pH units	NTU	no./1ml	Pt-Co	Descrip-tive	Descrip-tive	mg/l	mg/l	mg/l	µg/l	mg/l	mg/l		
Graigue Pouldine Zone 2: Turtulla	2800PRI2250	GWS - Group A Parameters	18-Jan-2022	-	0 ***	640 ***	0 ***	7.3 ***	<0.2 ***	1 ***	<5 ***	OK	OK	0.41	19.27 ***	0.48					
Graigue Pouldine Zone 2: Turtulla	2800PRI2250	GWS - Group A Parameters	9-Nov-2022	-	0 ***	651 ***	0 ***	7.3 ***	0.22 ***	<1 ***	<5 ***	OK	OK	0.47	17.08 ***	0.61					
Gurteenakilla	2800PRI2094	GWS - Group A Parameters	26-Jan-2022	-	0 ***	425 ***	0 ***	7 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	1.02	25.47 ***	1.25					
Gurteenakilla	2800PRI2094	GWS - Group A Parameters	20-Sep-2022	-	0 ***	425 ***	0 ***	7.1 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.61	25.09 ***	0.63					
Inchirourke	2900PRI0145	GWS - Group A Parameters	5-May-2022	-	0 ***	730 ***	0 ***	7.3 ***	<0.2 ***	<1 ***	<5 ***	Ok	Ok	0.08	32.13 ***	0.16					
Inchirourke	2900PRI0145	GWS - Group A Parameters	25-Oct-2022	-	0 ***	736 ***	0 ***	7.3 ***	<0.2 ***	<1 ***	10 ***	OK	OK	0.44	34.36 ***	0.7					
Kilbarron	2800PRI2005	GWS - Group A Parameters	15-Mar-2022	-	0 ***	438 ***	0 ***	7.3 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.89	7.31 ***	1.21					
Kilbarron	2800PRI2005	GWS - Group A Parameters	14-Sep-2022	-	0 ***	599 ***	0 ***	7.5 ***	<0.2 ***	7 ***	<5 ***	OK	OK	0.14	15.25 ***	0.18					
Kilcoran Group Water Scheme	2900PRI0226	GWS - Group A Parameters	5-May-2022	-	0 ***	226 ***	0 ***	6.7 ***	<0.2 ***	<1 ***	<5 ***	Ok	Ok	0.64	2.62 ***	0.66					
Kilcoran Group Water Scheme	2900PRI0226	GWS - Group A Parameters	25-Oct-2022	-	0 ***	241 ***	0 ***	6.6 ***	0.27 ***	<1 ***	5 ***	OK	OK	0.37	2.67 ***	0.47					
Killeen A	2800PRI2155	GWS - Group A Parameters	31-Jan-2022	-	0 ***	341 ***	0 ***	7.4 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.02	8.81 ***	0.04					
Killeen A	2800PRI2155	GWS - Group A Parameters	21-Sep-2022	-	0 ***	339 ***	0 ***	7.5 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.05	10.21 ***	0.05					
Knock Roscrea	2800PRI2093	GWS - Group A Parameters	19-Jan-2022	-	0 ***	492 ***	0 ***	7.1 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.01	16.27 ***	0.02					
Knock Roscrea	2800PRI2093	GWS - Group A Parameters	26-Oct-2022	-	0 ***	535 ***	0 ***	7.1 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.04	17.51 ***	0.06					
Lacka	2800PRI2071	GWS - Group A Parameters	16-Mar-2022	-	0 ***	660 ***	0 ***	7.3 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.42	16.07 ***	0.46					
Lacka	2800PRI2071	GWS - Group A Parameters	15-Nov-2022	-	0 ***	634 ***	0 ***	7.4 ***	<0.2 ***	1 ***	<5 ***	OK	OK	0.08	32.2 ***	0.28					
Lisheenacloonta	2800PRI2223	GWS - Group A Parameters	26-Jan-2022	-	0 ***	681 ***	0 ***	7.2 ***	<0.2 ***	>300 ***	<5 ***	OK	OK	0.02	50.07 ***	0.05					
Lisheenacloonta	2800PRI2223	GWS - Group A Parameters	21-Sep-2022	-	0 ***	711 ***	0 ***	7.3 ***	2.86 ***	<1 ***	53 ***	OK	OK	0.32	41.32 ***	0.35					
Luska	2800PRI2104	GWS - Group A Parameters	15-Mar-2022	-	0 ***	742 ***	0 ***	7.4 ***	<0.2 ***	<1 ***	5 ***	OK	OK	0.6	44.1 ***	0.64		<0.03 ***			
Luska	2800PRI2104	GWS - Group A Parameters	7-July-2022	-	0 ***	676 ***	0 ***	7.2 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.34	27.65 ***	0.53		<0.03 ***			
Mota/ Coolbawn	2800PRI2243	GWS - Group A Parameters	15-Mar-2022	-	0 ***	732 ***	0 ***	7.4 ***	<0.2 ***	1 ***	<5 ***	OK	OK	0.13	9.63 ***	0.17					
Mota/ Coolbawn	2800PRI2243	GWS - Group A Parameters	7-July-2022	-	0 ***	730 ***	0 ***	7.3 ***	<0.2 ***	7 ***	<5 ***	OK	OK	0.19	10.6 ***	0.2					
Moyne	2800PRI2030	GWS - Group A Parameters	18-Jan-2022	-	0 ***	690 ***	0 ***	7.3 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.23	30.54 ***	0.35					
Moyne	2800PRI2030	GWS - Group A Parameters	29-Mar-2022	-	0 ***	709 ***	0 ***	7.3 ***	<0.2 ***	1 ***	7 ***	OK	OK	0.31	36.17 ***	0.41					
Moyne	2800PRI2030	GWS - Group A Parameters	6-Sep-2022	-	0 ***	706 ***	0 ***	7.4 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.35	21.72 ***	0.42					
Moyne	2800PRI2030	GWS - Group A Parameters	2-Nov-2022	-	0 ***	657 ***	0 ***	7.3 ***	<0.2 ***	8 ***	<5 ***	OK	OK	0.08	42.85 ***	0.15					
Newhill	2800PRI2109	GWS - Group A Parameters	24-Jan-2022	-	0 ***	768 ***	0 ***	7.4 ***	<0.2 ***	5 ***	<5 ***	OK	OK	0.01	29.63 ***	0.07					
Newhill	2800PRI2109	GWS - Group A Parameters	18-Aug-2022	-	0 ***	766 ***	0 ***	7.5 ***	<0.2 ***	9 ***	<5 ***	OK	OK	0.02	26.65 ***	0.07					
Patrickswell	2800PRI2137	GWS - Group A Parameters	17-Jan-2022	-	0 ***	266 ***	0 ***	7.2 ***	<0.2 ***	7 ***	<5 ***	OK	OK	0.56	23.65 ***	0.63					
Patrickswell	2800PRI2137	GWS - Group A Parameters	5-Apr-2022	-	0 ***	312 ***	0 ***	6.8 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.71	32.37 ***	0.75					
Patrickswell	2800PRI2137	GWS - Group A Parameters	21-Sep-2022	-	0 ***	356 ***	0 ***	7.3 ***	0.21 ***	<1 ***	<5 ***	OK	OK	0.48	24.14 ***	0.55					
Patrickswell	2800PRI2137	GWS - Group A Parameters	22-Nov-2022	-	0 ***	227 ***	0 ***	7.2 ***	<0.2 ***	3 ***	<5 ***	OK	OK	0.67	16.06 ***	0.76					
Rahealty	2800PRI2190	GWS - Group A Parameters	18-Jan-2022	-	0 ***	696 ***	0 ***	7.5 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.33	16.44 ***	0.36					
Rahealty	2800PRI2190	GWS - Group A Parameters	29-Mar-2022	-	0 ***	702 ***	0 ***	7.3 ***	<0.2 ***	5 ***	6 ***	OK	OK	0.31	17.08 ***	0.33					
Rahealty	2800PRI2190	GWS - Group A Parameters	6-Sep-2022	-	0 ***	707 ***	0 ***	7.2 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.48	17.27 ***	0.52					
Rahealty	2800PRI2190	GWS - Group A Parameters	2-Nov-2022	-	0 ***	704 ***	0 ***	7.2 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.4	16.91 ***	0.41					
Rathfalla	2800PRI2285	GWS - Group A Parameters	26-Jan-2022	-	0 ***	660 ***	0 ***	7.2 ***	<0.2 ***	6 ***	<5 ***	OK	OK		29.61 ***						
Rathfalla	2800PRI2285	GWS - Group A Parameters	4-Oct-2022	-	0 ***	654 ***	0 ***	7.3 ***	<0.2 ***	<1 ***	<5 ***	OK	OK		27.26 ***						
Shallee	2800PRI2284	GWS - Group A Parameters	17-Jan-2022	-	2 ***	598 ***	0 ***	7.4 ***	<0.2 ***	6 ***	<5 ***	OK	OK	0.13	8.97 ***	0.15					
Shallee	2800PRI2284	GWS - Group A Parameters	5-Apr-2022	-	0 ***	634 ***	0 ***	7.3 ***	<0.2 ***	16 ***	<5 ***	OK	OK	0	10.55 ***	0					
The Pike Ballingarry	2800PRI2198	GWS - Group A Parameters	16-Mar-2022	-	0 ***	595 ***	0 ***	7.5 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.16	10.52 ***	0.19					
The Pike Ballingarry	2800PRI2198	GWS - Group A Parameters	15-Nov-2022	-	0 ***	626 ***	0 ***	7.4 ***	<0.2 ***	5 ***	<5 ***	OK	OK	0	17.47 ***	0					
Tonagha / Drish / Galboola	2800PRI2108	GWS - Group A Parameters	18-Jan-2022	-	0 ***	723 ***	0 ***	7.2 ***	<0.2 ***	4 ***	<5 ***	OK	OK	0	37.93 ***	0					
Tonagha / Drish / Galboola	2800PRI2108	GWS - Group A Parameters	9-Nov-2022	-	0 ***	735 ***	0 ***	7.2 ***	<0.2 ***	<1 ***	<5 ***	OK	OK	0.34	28.7 ***	0.47					

\* Accredited \*\*Sub-Contract \*\*\*Accredited Sub-Contract